

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE

INCIDENT NUMBER: CVE 2013 08 13 05 01

Location of Incident: **106 - 2200 53 RD AVE
VERNON BC**

of Occupants (At time of fire): **1** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **s.22**

Related to Wildland Interface Fire: **NO** Property Value: **s.22** Content Value: **s.22** Total Value at Risk: **s.22**

Code Name : Code Description

PROPERTY COMPLEX : 3400 RESIDENTIAL - SINGLE DETACHED
PROPERTY CLASSIFICATION : 3110 YEAR-ROUND USE DWELLING - 1-FAMILY
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST
BUILDING HEIGHT : 0010 1 STORY ABOVE GRADE
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)
YEAR OF CONSTRUCTION : 2005 2005
MANUAL FIRE PROTECTION : 7000 NO MANUAL FIRE PROTECTION
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 6000 ALARM NOT ACTIVATED - UNSUITABLE LOCATION
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 3000 COMPOSITE - CAREER & VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4300 38MM/42MM (1 1/2"/1 3/4") HOSE - 2 OR MORE HAND LINES
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)
FIRE ORIGIN, AREA : 7600 EXTERIOR WALL
EXTENT OF FIRE : 6000 EXTENDED BEYOND PROPERTY OF ORIGIN
EXTENT OF DAMAGE : 6000 EXTENDED BEYOND BUILDING OF ORIGIN
IGNITING OBJECT : 5100 PERMANENT ELECTRIC WIRING, CABLE (NON-ALUMINUM) - INCLUDES P
FUEL OR ENERGY : 6000 ELECTRICITY
FORM OF HEAT : 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI
MATERIAL FIRST IGNITED : 3000 EXTERIOR WALL COVERING, SURFACE, FINISH - INCLUDES EAVE
ACT OR OMISSION : 4400 ELECTRICAL SHORT CIRCUIT

Investigating Officer LAFC Badge #
SKOLROOD, LAWRIE 735

Telephone ReportDate
250-550-3563 2014-01-20

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **CVE 2013 08 13 05 01**

Remarks:

THE CAUSE OF THIS FIRE WAS AN ELECTRICAL FAILURE IN THE METER BASE FOR THIS DWELLING. DUE TO THE AMOUNT OF DAMAGE, THE CAUSE OF THIS FAILURE AND THE RESULTING ARC FLASH WAS NOT DETERMINED

Investigating Officer	L AFC Badge #
SKOLROOD, LAWRIE	735

Telephone	ReportDate
250-550-3563 	2014-01-20

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CVE 2013 08 13 05 01**

Name no. : 1
Name : s.22
Address : 106 - 2200 53RD AVE.
VERNON BRITISH COLUMBIA

Name Status : OWNER
Phone : s.22

Claims Adjuster Name : 1. DOLLINGER , ANDREA
Claims Adjuster Firm : 1. CLAIMS PRO
Claim Number :
Insurance Company : 1. GORE MUTUAL
Policy Number : s.22

LOSS ESTIMATES:

Property Loss : s.22

Content Loss : s.22

Total Loss : s.22

REMARKS:

Investigating Officer : LAFC Badge #
SKOLROOD, LAWRIE : 735

Telephone : 250-550-3563 
ReportDate : 2014-01-20

