

Location of Incident: **7246 SPRUCE GROVE CIRCLE
WHISTLER BC V0N 1B7**

of Occupants (At time of fire): **0** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **s.22**

Related to Wildland Interface Fire: **NO** Property Value: **s.22** Content Value: **s.22** Total Value at Risk: **s.22**

Code Name : Code Description

PROPERTY COMPLEX : 3400 RESIDENTIAL SINGLE DETACHED
PROPERTY CLASSIFICATION : 3160 SEASONAL USE DWELLING OFF SEASON, 2 FAMILY
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION WOOD PROTECTED BY PLAST
BUILDING HEIGHT : 0030 3 STORIES ABOVE GRADE
GROUND FLOOR AREA : 1000 1 TO 100M2 (1 1076FT2)
YEAR OF CONSTRUCTION : 2000 2000
MANUAL FIRE PROTECTION : 0000 CANNOT BE DETERMINED
OUTSIDE FIRE PROTECTION : 7000 FIRE DEPARTMENT ONLY
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 0000 ALARM OPERATION CANNOT BE DETERMINED
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 3000 COMPOSITE CAREER & VOLUNTEER/PAID ON CALL FIRE DEPARTMENT
INCIDENT : 1000 FIRE FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4300 38MM/42MM (1 1/2"/1 3/4") HOSE 2 OR MORE HAND LINES
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)
FIRE ORIGIN, AREA : 4700 VEHICLE STORAGE INCLUDES GARAGE, CARPORT. (EXCLUDES OUTSID
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN
EXTENT OF DAMAGE : 6000 EXTENDED BEYOND BUILDING OF ORIGIN
IGNITING OBJECT : 9810 SPONTANEOUS COMBUSTION
FUEL OR ENERGY : 0009 FUEL OR ENERGY UNCLASSIFIED (DESCRIBE)
FORM OF HEAT : 7000 SPONTANEOUS OR CHEMICAL CAUSATION
MATERIAL FIRST IGNITED : 9700 OILY RAGS INCLUDES PAINT RAGS, WASTE IMPREGNATED WITH PETR
ACT OR OMISSION : 3900 MISUSE OF MATERIAL IGNITED UNCLASSIFIED (DESCRIBE)

Investigating Officer
PLAYFAIR, GEOFF

LAFC Badge #
2347

Telephone
604 935 8260

ReportDate
2010 09 27

Remarks:

PAINTERS HAD BEEN AT THE HOME OVER THE COURSE OF THE WEEK PAINTING THE HOME. OWNERS WERE NOT AT HOME. DUE TO WET WEATHER, THE PAINTERS AHD REMOVED DECK RAILS AND PICKETS AND STACKED IN THE GARAGE TO VARNISH. AFTER TWO COATS WERE APPLIED, THE WORKER FINISHED THE DAY, LEAVING SOME WWRAGS OUT TO AIR IN THE HOPE OF USING THEM AGAIN. THE MSDS FOR THE PRODUCT SUGGESTS EMERSING WET WRAGS IN WATER TO AVOID SPONTANEOUS COMBUSTION. ABOUT 8 HOURS AFTER THE PAINTERS LEFT FRO THE DAY, A NEIGHBOUR WOKE TO SEE FLAMES COMING FROM THE GARAGE OF THE HOUSE. HE CALLED 911.

Investigating Officer	LAFC Badge #	Telephone	ReportDate
PLAYFAIR, GEOFF	2347	604 935 8260	2010 09 27

Name no. : 1
Name : s.22
Address : 7246 SPRUCE GROVE CIRCLE
WHISTLER BRITISH COLUMBIA V0N 1B7

Name Status : OWNER
Phone : s.22

Claims Adjuster Name : 1. ANDERSON , BOB
Claims Adjuster Firm : 1. ALAN VANDRPARK & ASSOC.
Claim Number :
Insurance Company : 1. ALLEN VANDER PARK & ASSOC.
Policy Number :

LOSS ESTIMATES:

Property Loss : s.22 Content Loss : s.22 Total Loss : s.22

REMARKS:

THE HOMES GARAGE IS A TOTAL LOSS WITH LESSER FIRE, WATER AND SMOKE DAMAGES TO THE SECOND, THIRD FLOORS AND TOWARDS THE FRONT OF THE OCCUPANCY.

Name no. : 2
Name : s.22
Address : 7246 SPRUCE GROVE CIRCLE
WHISTLER V0N 1B7

Name Status : OWNER
Phone : s.22

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0 Content Loss : \$0 Total Loss : \$0

REMARKS:

O W0NERS OF 7248 SPRUCE GROVE CIRCLE. s.22

Investigating Officer
PLAYFAIR, GEOFF

LAFC Badge #
2347

Telephone
604 935 8260

ReportDate
2010 09 27