

PROVINCE OF BRITISH COLUMBIA
Ministry of Public Safety and Solicitor General
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE**

INCIDENT NUMBER: **CBU 2011 08 29 13
01**

Location of Incident: **5820 BYRNE ROAD
BURNABY BC**

of Occupants (At time of fire): **2** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **s.22**

Related to Wildland Interface Fire: **NO** Property Value: **s.22** Content Value: **s.22** Total Value at Risk: **s.22**

Code Name : Code Description

PROPERTY COMPLEX : 0009 BUILDING/STRUCTURE UNCLASSIFIED (DESCRIBE)
PROPERTY CLASSIFICATION : 7971 INDOOR STORAGE (WITHIN A BUILDING OR STRUCTURE)
GENERAL CONSTRUCTION : 1000 COMBUSTIBLE CONSTRUCTION - OPEN WOOD JOIST
BUILDING HEIGHT : 0010 1 STORY ABOVE GRADE
GROUND FLOOR AREA : 6000 5001 TO 10,000M2 (53821 - 107640FT2)
YEAR OF CONSTRUCTION : 0061 1961 TO 1965
MANUAL FIRE PROTECTION : 4000 EXTINGUISHER ONLY
OUTSIDE FIRE PROTECTION : 7000 FIRE DEPARTMENT ONLY
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 3000 FIRE ALARM SYSTEM - OFF-SITE MONITORING AGENCY
SMOKE ALARM OPERATION : 0000 ALARM OPERATION CANNOT BE DETERMINED
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 1000 CAREER FIRE DEPARTMENT ONLY
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4500 65MM/77MM (2 1/2"/3") HOSE -2 OR MORE HAND LINES
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)
FIRE ORIGIN, AREA : 9900 OUTSIDE AREA - UNCLASSIFIED (DESCRIBE)
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN

IGNITING OBJECT : 7500 CUTTING TORCH

FUEL OR ENERGY : 0000 CANNOT BE DETERMINED

FORM OF HEAT : 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI

MATERIAL FIRST IGNITED : 4600 WASTEPAPER - (EXCLUDES GARBAGE, TRASH CLASSIFIED UNDER 960.)

ACT OR OMISSION : 7700 IGNORANCE OF HAZARD (NOTE: IF ILLEGAL OPERATIONS, CLASSIFY A

Investigating Officer	LAFC Badge #	Telephone	ReportDate
WENSLEY, DAVE	249	604-294-7195	2011-09-28

PROVINCE OF BRITISH COLUMBIA
Ministry of Public Safety and Solicitor General

FIRE REPORT - **STRUCTURE** (NARRATIVE)

Emergency Management BC / Office of the Fire Commissioner

INCIDENT NUMBER: **CBU 2011 08 29 13
01**

Remarks:

WORKERS STARTED FIRE WITH A CUTTING TORCH (HOT WORKS) ON THE EXTERIOR OF THE ADDRESS SIDE OF THE BUILDING.

Investigating Officer	LAFC Badge #	Telephone	ReportDate
WENSLEY, DAVE	249	604-294-7195	2011-09-28

PROVINCE OF BRITISH COLUMBIA
Ministry of Public Safety and Solicitor General

FIRE REPORT - **STRUCTURE** (NAMES)

Emergency Management BC / Office of the Fire Commissioner

INCIDENT NUMBER: **CBU 2011 08 29 13 01**

Name no.	: 1	Name Status	: WITNESS
Name	:	Phone	: s.22
Address	:		

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0	Content Loss : \$0	Total Loss : \$0
---------------------	--------------------	------------------

REMARKS:

s.22 WITNESSED HIS s.22 CUTTING METAL WITH A TORCH AND A SMALL
FIRE STARTED BELOW WHERE THE CUTTING WAS TAKING PLACE. s.22 RAN TO FIND A MEANS TO
CONTROL THE FIRE BUT TO AVAIL. THE FIRE QUICKLY SPREAD TO THE BUILDING AND THROUGH OUT.

Name no.	: 2	Name Status	: OWNER
----------	-----	-------------	---------

Name :
Address : s.22

Phone : s.22

Claims Adjuster Name :
Claims Adjuster Firm : s.22
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Content Loss : s.22 Total Loss : s.22
Loss : s.22

REMARKS:

Investigating Officer	LAFC Badge #	Telephone	ReportDate
WENSLEY, DAVE	249	604-294-7195	2011-09-28