

Location of Incident: **2284 ORCHARD DR  
ABBOTSFORD BC**

# of Occupants (At time of fire): 0    # of Injured: 0    # of Deaths: 0    Total Dollar Loss Estimate: s. 22

Related to Wildland Interface Fire: NO    Property Value: s. 22    Content Value: s. 22    Total Value at Risk: s. 22

**Code Name :      Code Description**

PROPERTY COMPLEX : 3400 RESIDENTIAL - SINGLE DETACHED  
PROPERTY CLASSIFICATION : 3110 YEAR-ROUND USE DWELLING - 1-FAMILY  
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST  
BUILDING HEIGHT : 0010 1 STORY ABOVE GRADE  
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)  
YEAR OF CONSTRUCTION : 0000 CANNOT BE DETERMINED  
MANUAL FIRE PROTECTION : 7000 NO MANUAL FIRE PROTECTION  
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT  
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION  
AUTOMATIC FIRE ALARM SYSTE : 0000 CANNOT BE DETERMINED  
SMOKE ALARM OPERATION : 0000 ALARM OPERATION CANNOT BE DETERMINED  
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S  
TRANSMISSION OF ALARM : 1000 911  
FIRE SERVICE : 3000 COMPOSITE - CAREER & VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT  
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED  
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT  
METHOD OF FIRE CONTROL : 4300 38MM/42MM (1 1/2"/1 3/4") HOSE - 2 OR MORE HAND LINES  
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)  
FIRE ORIGIN, AREA : 2100 SLEEPING - UNDER 5 OCCUPANTS - INCLUDES PATIENTS' ROOM, BEDR  
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN  
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN  
IGNITING OBJECT : 6200 MOTOR UNDER IHP - INCLUDES MOTOR FORMING AN INTEGRAL PART OF  
FUEL OR ENERGY : 6000 ELECTRICITY  
FORM OF HEAT : 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI  
MATERIAL FIRST IGNITED : 7300 PLASTICS - (EXCLUDES CELLULOSE NITRATE CLASSIFIED UNDER 720.  
ACT OR OMISSION : 7700 IGNORANCE OF HAZARD (NOTE: IF ILLEGAL OPERATIONS, CLASSIFY A

Investigating Officer    LAFC Badge #  
MAIN, TED                1320

Telephone    ReportDate  
604-853-3566    2011-07-25

**Remarks:**

NO TEXT IN THIS SPACE

Investigating Officer  
MAIN, TED

LAFC Badge #  
1320

Telephone  
604-853-3566

ReportDate  
2011-07-25

PROVINCE OF BRITISH COLUMBIA  
Ministry of Public Safety and Solicitor General  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE (NAMES)

INCIDENT NUMBER: CAB 2011 07 04 21 01

Name no. :  
Name : s. 22  
Address : 0 2284 ORCHARD DR  
ABBOTSFORD BRITISH COLUMBIA V3G2B7

Name Status : OWNER  
Phone : s. 22

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : s. 22

Content Loss : \$0

Total Loss : s. 22

REMARKS:

---

Investigating Officer	LAFC Badge #	Telephone	ReportDate
MAIN, TED	1320	604-853-3566	2011-07-25

