

Location of Incident:

**2307 SKAHA LK RD
PENTICTON BC**

of Occupants (At time of fire): **1** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **s.22**

Related to Wildland Interface Fire: **NO** Property Value: **s.22** Content Value: **s.22** Total Value at Risk: **s.22**

Code Name : Code Description

PROPERTY COMPLEX : 3300 HOTEL, MOTEL, LODGE, HOSTEL, BOARDING HOUSE, DORMITORY
PROPERTY CLASSIFICATION : 3420 HOTEL, INN, LODGE - SEASONAL USE, IN SEASON
GENERAL CONSTRUCTION : 5000 PROTECTED NON-COMBUSTIBLE CONSTRUCTION - PROTECTED STEEL OR
BUILDING HEIGHT : 0020 2 STORIES ABOVE GRADE
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)
YEAR OF CONSTRUCTION : 0061 1961 TO 1965
MANUAL FIRE PROTECTION : 4000 EXTINGUISHER ONLY
OUTSIDE FIRE PROTECTION : 7000 FIRE DEPARTMENT ONLY
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 8000 ALARM NOT ACTIVATED - AC POWER NOT CONNECTED, DISABLE OR OFF
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 3000 COMPOSITE - CAREER & VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 1000 EXTINGUISHED BY OTHER THAN FIRE DEPARTMENT (I.E.. OCCUPANT/W
METHOD OF FIRE CONTROL : 1200 WATER PRESSURIZED
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)
FIRE ORIGIN, AREA : 2500 WASHROOM, LOCKER AREA - INCLUDES CHECKROOM, CLOAKROOM, REST
EXTENT OF FIRE : 3000 CONFINED TO ROOM OF ORIGIN
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN
IGNITING OBJECT : 2900 HEATING EQUIPMENT - UNCLASSIFIED (DESCRIBE)
FUEL OR ENERGY : 6000 ELECTRICITY
FORM OF HEAT : 6000 HOT OBJECT - DIRECT HEAT BY CONDUCTION OR RADIATION, NO DIRE
MATERIAL FIRST IGNITED : 3400 FABRIC - COTTON - INCLUDES FINISHED GOODS. (EXCLUDES FIBRE,
ACT OR OMISSION : 2430 ADULT - 18 YEARS OF AGE AND OLDER

Investigating Officer
SPALDING, DAVE

LAFC Badge #
1630

Telephone
250-490-2300

ReportDate
2013-05-06

Remarks:

FIRE STARTED FROM TOWELS BEING PUISHED UP AGAINST ELECTRIC BASE BOARD HEATER

Investigating Officer	LAFB Badge #	Telephone	ReportDate
SPALDING, DAVE	1630	250-490-2300	2013-05-06

Name no. : 1
Name :
Address :

s.22

Name Status : OCCUPANT
Phone s.22

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : s.22

Content Loss : s.22

Total Loss : s.22

REMARKS:

FIRE IN BATHROOM OF UNIT

Investigating Officer
SPALDING, DAVE

LAFC Badge #
1630

Telephone
250-490-2300

ReportDate
2013-05-06