

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE

INCIDENT NUMBER: RTN 2014 04 16 22 01

Location of Incident:

**2536 HARPER RANCH PINANTAN ROAD
THOMPSON-NICOLA REGIONAL DISTRICT BC**

of Occupants (At time of fire): **1** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: \$ **s.21**

Related to Wildland Interface Fire: **NO** Property Value: \$ **s.21** Content Value: \$ **s.21** Total Value at Risk: \$ **s.21**

Code Name : Code Description

PROPERTY COMPLEX : 5800 DEPARTMENT STORE, VARIETY STORE
PROPERTY CLASSIFICATION : 5120 MARKET, GROCERY STORES - LESS THAN 1000M2 (10764 FT2)
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST
BUILDING HEIGHT : 0010 1 STORY ABOVE GRADE
GROUND FLOOR AREA : 3000 501 TO 1000M2 (5383 - 10764FT2)
YEAR OF CONSTRUCTION : 0000 CANNOT BE DETERMINED
MANUAL FIRE PROTECTION : 0000 CANNOT BE DETERMINED
OUTSIDE FIRE PROTECTION : 0009 OUTSIDE FIRE PROTECTION - UNCLASSIFIED (DESCRIBE)
SPRINKLER PROTECTION : 0000 CANNOT BE DETERMINED
AUTOMATIC FIRE ALARM SYSTE : 0000 CANNOT BE DETERMINED
SMOKE ALARM OPERATION : 0000 ALARM OPERATION CANNOT BE DETERMINED
INITIAL DETECTION : 0009 INITIAL DETECTION - UNCLASSIFIED (DESCRIBE)
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 8000 NO FIRE SERVICE
INCIDENT : 1100 NO ALARM FIRE - NOT RESPONDED TO BY FIRE DEPARTMENT
ACTION TAKEN : 2000 BURNED OUT - NO EXTINGUISHMENT ATTEMPTED/NEEDED
METHOD OF FIRE CONTROL : 8300 BURNED OUT, NO EXTINGUISHMENT - OUTSIDE FIRE PROTECTION AREA
FIRE ORIGIN, LEVEL : 1000 BASEMENT, SUB-BASEMENT
FIRE ORIGIN, AREA : 6200 HEATING EQUIPMENT ROOM - INCLUDES FURNACE ROOM, WATER HEATER
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN
IGNITING OBJECT : 2100 CENTRAL HEATING UNIT - INCLUDES FURNACE, BOILER, STOKER
FUEL OR ENERGY : 6000 ELECTRICITY
FORM OF HEAT : 0000 CANNOT BE DETERMINED
MATERIAL FIRST IGNITED : 0000 CANNOT BE DETERMINED
ACT OR OMISSION : 4900 MECHANICAL/ELECTRICAL FAILURE/MALFUNCTION - UNCLASSIFIED (DE

Investigating Officer
GIGUERE, MARTIN

LAFC Badge #
CST.

Telephone ReportDate
250-314-1800 2014-07-11

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)


INCIDENT NUMBER: **RTN 2014 04 16 22 01**

Remarks:

IT IS BELIEVED THE FIRE ORIGINATED IN THE FURNACE ROOM LOCATED BELOW THE RENTAL SUITE AT THE BACK OF THE STORE. INITIAL DETECTION - NEIGHBOURS AND TENANT IN LIVING AREA AT REAR OF STORE.

Investigating Officer
GIGUERE, MARTIN

LAFC Badge #
CST.

Telephone
250-314-1800 

ReportDate
2014-07-11

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **RTN 2014 04 16 22 01**

Name no. : 1
Name : GEORGE, CORY KEVIN GARY
Address : 2536 HARPER RANCH PINANTEN ROAD
PINANTAN LAKE BRITISH COLUMBIA

Name Status : BUSINESS OWNER
Phone : 250-573-4446

Claims Adjuster Name : 1. SMITH , PAUL A.
Claims Adjuster Firm : 1. HUSTON GRANT ADJUSTERS
Claim Number :
Insurance Company : 1. HUSTON GRANT ADJUSTERS
Policy Number :

LOSS ESTIMATES:

Property Loss : \$ **s.21**Content Loss : **s.21**Total Loss : **s.21**

REMARKS:

Investigating Officer
GIGUERE, MARTIN

LAFC Badge #
CST.

Telephone
250-314-1800

ReportDate
2014-07-11

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE**INCIDENT NUMBER: **NWG 2014 04 10 08 01**

Location of Incident: **4210 PACIFIC ROAD
WILDWOOD BC V2G4Z8**

of Occupants (At time of fire): **1** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: \$ **s.22**

Related to Wildland Interface Fire: **NO** Property Value: **\$0** Content Value: **\$0** Total Value at Risk: **\$0**

Code Name : Code Description

PROPERTY COMPLEX : 3800 RESIDENTIAL - MOBILE HOME/TRAILER PARK
PROPERTY CLASSIFICATION : 3110 YEAR-ROUND USE DWELLING - 1-FAMILY
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST
BUILDING HEIGHT : 0010 1 STORY ABOVE GRADE
GROUND FLOOR AREA : 1000 1 TO 100M2 (1 - 1076FT2)
YEAR OF CONSTRUCTION : 1970 1970
MANUAL FIRE PROTECTION : 7000 NO MANUAL FIRE PROTECTION
OUTSIDE FIRE PROTECTION : 0009 OUTSIDE FIRE PROTECTION - UNCLASSIFIED (DESCRIBE)
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 9900 NO SMOKE ALARM INSTALLED
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 2000 VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT ONLY
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4300 38MM/42MM (1 1/2"/1 3/4") HOSE - 2 OR MORE HAND LINES
FIRE ORIGIN, LEVEL : 2000 CRAWL SPACE, UNDER STRUCTURE
FIRE ORIGIN, AREA : 7100 CRAWL SPACE - INCLUDES SUB-STRUCTURE SPACE
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN
IGNITING OBJECT : 3300 CLOTHES DRYER
FUEL OR ENERGY : 6000 ELECTRICITY
FORM OF HEAT : 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI
MATERIAL FIRST IGNITED : 3300 CLOTHING - SYNTHETIC FIBRE - INCLUDES MIXED FIBRES
ACT OR OMISSION : 6300 LACK OF MAINTENANCE

Investigating Officer LAFC Badge #
WORSLEY, RANDY 311

Telephone ReportDate
250-989-4462  2014-05-01

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **NWG 2014 04 10 08 01**

Remarks:

s.22

Investigating Officer	L AFC Badge #	Telephone	ReportDate
WORSLEY, RANDY	311	250-989-4462 	2014-05-01

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **NWG 2014 04 10 08 01**

Name no. : 1
Name : **s.22**
Address : 4210 PACIFIC ROAD
WILLIAMS LAKE BRITISH COLUMBIA V2G 4Z8

Name Status : OWNER
Phone :

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company : 1. BARTON INSURANCE
Policy Number :

LOSS ESTIMATES:

Property Loss : **s.22**

Content Loss : \$ **s.22**

Total Loss : **s.22**

REMARKS:

Investigating Officer
WORSLEY, RANDY

LAFC Badge #
311

Telephone
250-989-4462 

ReportDate
2014-05-01

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE

INCIDENT NUMBER: **CKE 2013 12 09 11 01**

Location of Incident: **496 ELDORADO RD
KELOWNA BC**

of Occupants (At time of fire): **0** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: \$ **s.22**

Related to Wildland Interface Fire: **NO** Property Value: **s.22** Content Value: **\$0** Total Value at Risk: \$ **s.22**

Code Name : Code Description

PROPERTY COMPLEX : 3400 RESIDENTIAL - SINGLE DETACHED
PROPERTY CLASSIFICATION : 3110 YEAR-ROUND USE DWELLING - 1-FAMILY
GENERAL CONSTRUCTION : 0009 GENERAL CONSTRUCTION - UNCLASSIFIED (DESCRIBE)
BUILDING HEIGHT : 0010 1 STORY ABOVE GRADE
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)
YEAR OF CONSTRUCTION : 1974 1974
MANUAL FIRE PROTECTION : 7000 NO MANUAL FIRE PROTECTION
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 9500 ALARM NOT ACTIVATED - UNKNOWN
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 3000 COMPOSITE - CAREER & VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4300 38MM/42MM (1 1/2"/1 3/4") HOSE - 2 OR MORE HAND LINES
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)
FIRE ORIGIN, AREA : 7600 EXTERIOR WALL
EXTENT OF FIRE : 6000 EXTENDED BEYOND PROPERTY OF ORIGIN
EXTENT OF DAMAGE : 6000 EXTENDED BEYOND BUILDING OF ORIGIN
IGNITING OBJECT : 5500 SWITCH, OUTLET - INCLUDES RECEPTACLE, SOCKET
FUEL OR ENERGY : 6000 ELECTRICITY
FORM OF HEAT : 0000 CANNOT BE DETERMINED
MATERIAL FIRST IGNITED : 3000 EXTERIOR WALL COVERING, SURFACE, FINISH - INCLUDES EAVE
ACT OR OMISSION : 4400 ELECTRICAL SHORT CIRCUIT

Investigating Officer LAFC Badge #
CALHOUN, DALE E

Telephone ReportDate
250-860-6419 2013-12-20

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **CKE 2013 12 09 11 01**

Remarks:

ELECTRICAL FIRE STARTED IN RECEPICAL CAUSING ABOUT **s.22** DAMAGE.

Investigating Officer
CALHOUN, DALE E

LAFC Badge #

Telephone
250-860-6419 

ReportDate
2013-12-20

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CKE 2013 12 09 11 01**

Name no. : 1
Name : **s.22**
Address : 0 469 ELDORADO ROAD
KELOWNA BRITISH COLUMBIA

Name Status : OCCUPANT
Phone : **s.22**

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : \$ **s.22**

Content Loss : \$0

Total Loss : \$ **s.22**

REMARKS:

Name no. : 2
Name : **s.22**
Address : 0

Name Status : OWNER
Phone :

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #
CALHOUN, DALE E

Telephone : 250-860-6419
ReportDate : 2013-12-20

