

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

## FIRE REPORT - STRUCTURE

INCIDENT NUMBER: **DNC 2013 09 27 06 01**

Location of Incident:

**4051 COWICHAN LAKE ROAD  
NORTH COWICHAN BC V9L 6J9**# of Occupants (At time of fire): **3**      # of Injured: **0**      # of Deaths: **0**      Total Dollar Loss Estimate: \$ **s.22**Related to Wildland Interface Fire: **NO**      Property Value: \$ **s.22**      Content Value: \$ **s.22**      Total Value at Risk: \$ **s.22****Code Name :      Code Description**

PROPERTY COMPLEX : 3400 RESIDENTIAL - SINGLE DETACHED  
PROPERTY CLASSIFICATION : 3110 YEAR-ROUND USE DWELLING - 1-FAMILY  
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST  
BUILDING HEIGHT : 0030 3 STORIES ABOVE GRADE  
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)  
YEAR OF CONSTRUCTION : 1974 1974  
MANUAL FIRE PROTECTION : 7000 NO MANUAL FIRE PROTECTION  
OUTSIDE FIRE PROTECTION : 7000 FIRE DEPARTMENT ONLY  
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION  
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM  
SMOKE ALARM OPERATION : 9500 ALARM NOT ACTIVATED - UNKNOWN  
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S  
TRANSMISSION OF ALARM : 1000 911  
FIRE SERVICE : 2000 VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT ONLY  
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED  
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT  
METHOD OF FIRE CONTROL : 4700 COMBINATIONS OF 38/42MM (1 1/2"/1 3/4"), 65MM (2 1/2"), 7  
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)  
FIRE ORIGIN, AREA : 4700 VEHICLE STORAGE - INCLUDES GARAGE, CARPORT. (EXCLUDES OUTSID  
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN  
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN  
IGNITING OBJECT : 0000 CANNOT BE DETERMINED  
FUEL OR ENERGY : 0000 CANNOT BE DETERMINED  
FORM OF HEAT : 0000 CANNOT BE DETERMINED  
MATERIAL FIRST IGNITED : 0000 CANNOT BE DETERMINED  
ACT OR OMISSION : 0000 CANNOT BE DETERMINED

Investigating Officer  
CLARK, ROBERTLAFC Badge #  
999Telephone  
250-746-3100ReportDate  
2013-10-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **DNC 2013 09 27 06 01**

---

**Remarks:**

THE FIRE ORIGINATED IN THE SOUTHWEST CORNER OF AN ATTACHED 16 X 30 FOOT GARAGE. THE GARAGE WAS USED FOR THE STORAGE OF **s.22** EQUIPMENT AND GENERAL HOUSEHOLD USE ITEMS. ON THE FLOOR OF THE GARAGE WAS APPROXIMATELY **s.22** THE CAUSE OF THE FIRE WAS NOT DETERMINED.

---

Investigating Officer  
CLARK, ROBERT

LAFC Badge #  
999

Telephone  
250-746-3100 

ReportDate  
2013-10-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **DNC 2013 09 27 06 01**

Name no. : 1  
Name : s.22  
Address : 4051 COWICHAN LAKE ROAD  
DUNCAN BRITISH COLUMBIA V9L 6J9  
  
Claims Adjuster Name : 1. POWELL , BRUCE  
Claims Adjuster Firm : 1. ASSOCIATED INDEPENDENT ADJUSTERS  
Claim Number : 1 s.22  
Insurance Company : 1. GORE MUTUAL  
Policy Number : 1. s.22

Name Status : OWNER  
Phone :

## LOSS ESTIMATES:

Property Loss : \$ s.22

Content Loss : \$ s.22

Total Loss : \$ s.22

## REMARKS:

Name no. : 2  
Name : s.22  
Address : 4051 COWICHAN LAKE ROAD  
DUNCAN BRITISH COLUMBIA V9L 6J9

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

## REMARKS:

s.22 SON, ASLEEP AT THE TIME IN SECOND FLOOR BEDROOM.

Investigating Officer : LAFC Badge #  
CLARK, ROBERT : 999

Telephone : 250-746-3100  
ReportDate : 2013-10-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **DNC 2013 09 27 06 01**

Name no. : 3  
Name : **s.22**  
Address : 4051 COWICHAN LAKE ROAD  
DUNCAN BRITISH COLUMBIA V9L 6J9

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0


Total Loss : \$0

REMARKS:

**s.22** DAUGHTER, WAKENED BY SMOKE SMELL, MAIN FLOOR BEDROOM.

Investigating Officer  
CLARK, ROBERT

LAFC Badge #  
999

Telephone  
250-746-3100 

ReportDate  
2013-10-02



PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE**INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Location of Incident: **1 - 1400 WINGROVE ST  
NANAIMO BC**

# of Occupants (At time of fire): **9**      # of Injured: **6**      # of Deaths: **0**      Total Dollar Loss Estimate: **s.22**

Related to Wildland Interface Fire: **NO**      Property Value: \$ **s.22**      Content Value: **s.22**      Total Value at Risk: \$ **s.22**

**Code Name :      Code Description**

PROPERTY COMPLEX : 3900 RESIDENTIAL - WITH BUSINESS/MERCANTILE, UP TO 3 STORIES  
PROPERTY CLASSIFICATION : 1710 RESTAURANT - INCLUDES EATING PLACES SPECIALIZING IN FOOD PRI  
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST  
BUILDING HEIGHT : 0020 2 STORIES ABOVE GRADE  
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)  
YEAR OF CONSTRUCTION : 1976 1976  
MANUAL FIRE PROTECTION : 4000 EXTINGUISHER ONLY  
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT  
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION  
AUTOMATIC FIRE ALARM SYSTE : 2000 FIRE ALARM SYSTEM - LOCAL (BUILDING ONLY)  
SMOKE ALARM OPERATION : 1000 ALARM ACTIVATED - ASSISTED OCCUPANT(S) IN EVACUATING  
INITIAL DETECTION : 1000 SMOKE ALARM DEVICE  
TRANSMISSION OF ALARM : 1000 911  
FIRE SERVICE : 3000 COMPOSITE - CAREER & VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT  
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED  
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT  
METHOD OF FIRE CONTROL : 4300 38MM/42MM (1 1/2"/1 3/4") HOSE - 2 OR MORE HAND LINES  
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)  
FIRE ORIGIN, AREA : 7300 CEILING & FLOOR ASSEMBLY - INCLUDES CONCEALED FLOOR/CEILING  
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN  
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN  
IGNITING OBJECT : 5100 PERMANENT ELECTRIC WIRING, CABLE (NON-ALUMINUM) - INCLUDES P  
FUEL OR ENERGY : 6000 ELECTRICITY  
FORM OF HEAT : 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI  
MATERIAL FIRST IGNITED : 0000 CANNOT BE DETERMINED  
ACT OR OMISSION : 4400 ELECTRICAL SHORT CIRCUIT

Investigating Officer  
MOND, ENNIS

LAFC Badge #  
1030

Telephone      ReportDate  
250-753-7311  2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

---

**Remarks:**

THE TWO STOREY WOOD FRAME STRUCTURE WAS BUILT IN 1976 AS A COMMERCIAL/ RESIDENTIAL BUILDING. THE GROUND FLOOR CONTAINED THE COMMERCIAL UNITS AND THE UPPER FLOOR HAD FOUR RESIDENTIAL UNITS. ON THE DAY OF THE FIRE THE UPPER FLOOR HAD THREE OCCUPIED UNITS 101, 102, 103, WITH THE OCCUPANTS OF THE FOURTH UNIT 104 AWAY. THE GROUND FLOOR WAS ADDRESSED WITH UNIT 1 A RESTAURANT, UNIT 2 WAS UNDER A TENANT IMPROVEMENT AND BEING DIVIDED INTO TWO UNITS UNIT2 AND UNIT2B, UNIT 4 WAS A COFFEE SHOP, AND UNIT 5 WAS AN OFFICE. PRIOR TO THE FIRE IN THE NEW UNIT 2B ELECTRICAL CHANGES WERE MADE BY RELOCATING THE ELECTRICAL SERVICE PANEL FOR THE UNIT. DURING THE RELOCATION OF THE PANEL A JUNCTION BOX WAS INSTALLED ON THE CEILING OF THE NEW BATHROOM IN UNIT 2B. THE STRUCTURAL FRAMING BETWEEN THE CEILING AND THE UPPER FLOOR CONSISTED OF FLOOR JOIST TRUSSES SPANNING THE WIDTH OF THE BUILDING. THE JOIST TRUSSES WERE THREE FEET HIGH CREATING A VOID SPACE EXTENDING THE LENGTH OF THE BUILDING. IT WAS ALSO NOTED THAT THE FIRE SEPARATIONS FROM THE COMMERCIAL SPACES DID NOT EXTEND TO THE BOTTOM OF THE SECOND FLOOR. THE AREA OF ORIGIN WAS THE JOIST TRUSSES ABOVE UNIT 2B ABOVE THE NEW JUNCTION BOX. AFTER THE INSTALLATION OF THE NEW FEEDER LINE FROM THE JUNCTION BOX TO THE SERVICE PANEL A SHORT CIRCUIT OCCURRED AT THE JUNCTION BOX. THE POWER CABLES IN THE BOX SHORTED AGAINST THE METAL SIDE OF THE BOX AND PRODUCED MOLTEN METAL (SPARKS). THESE SPARKS EVENTUALLY IGNITED THE WOOD FRAMING OF THE JOIST TRUSSES. EVENTUALLY THE FIRE BURNING IN THE FLOOR STRUCTURE BURNED VERTICALLY UP AND INTO UNIT 102 A RESIDENTIAL UNIT. SMOKE SPREAD HORIZONTALLY THROUGH THE VOID SPACE IN THE CEILING AREA AFFECTING ALL OF THE COMMERCIAL UNITS ON THE GROUND FLOOR AND TO UNITS ON THE UPPER FLOOR.

---

Investigating Officer  
MOND, ENNIS

LAFC Badge #  
1030

Telephone  
250-753-7311

ReportDate  
2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 1  
Name : **s.22**  
Address : 0 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OWNER  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$ **s.22**

Content Loss : \$0

Total Loss : \$ **s.22**

REMARKS:

Name no. : 2  
Name : **s.22**  
Address : 0 101 AND 102 1400 WINGROVE ST  
NANAIMO BRITISH COLUMBIA

Name Status : OWNER  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$ **s.22**Total Loss : \$ **s.22**

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : 250-753-7311  ReportDate : 2013-12-02



PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 3  
Name : **s.22**  
Address : 0 101 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Name no. : 4  
Name : **s.22**  
Address : 0 101 1400 WINGROVE ST

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : 250-753-7311  ReportDate : 2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 5  
Name : **s.22**  
Address : 0 101 1400 WINGROVE ST  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Name no. : 6  
Name : **s.22**  
Address : 0 102 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : ReportDate  
250-753-7311  2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 7  
Name : **s.22**  
Address : 0 103 1400 WINGROVE STREET

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Name no. : 8  
Name : **s.22**  
Address : 0 103 1400 WINGROVE ST  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : ReportDate  
250-753-7311  2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 9  
Name : **s.22**  
Address : 0 104 1400 WINGROVE ST  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Name no. : 10  
Name : LEVENBERGER, PAMELA  
Address : 0

Name Status : BUSINESS OWNER  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : **s.21**Total Loss : \$ **s.21**

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : 250-753-7311  ReportDate : 2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 11  
Name : TUGNAIT, SAVITA  
Address : 0

Name Status : BUSINESS OWNER  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$ **s.21**Total Loss : \$ **s.21**

REMARKS:

Name no. : 12  
Name : **s.22**  
Address : 0 102 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OWNER  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

## LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : 250-753-7311  ReportDate : 2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 13  
Name : **s.22**  
Address : 0 102 1400 WINDGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Name no. : 14  
Name : **s.22**  
Address : 0 101 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : ReportDate  
250-753-7311  2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 15  
Name : **s.22**  
Address : 0 101 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Name no. : 16  
Name : **s.22**  
Address : 0 103 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #  
MOND, ENNIS : 1030

Telephone : 250-753-7311  ReportDate : 2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

Name no. : 17  
Name : **s.22**  
Address : 0 103 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer :  
MOND, ENNIS

L AFC Badge #  
1030

Telephone :  
250-753-7311

ReportDate  
2013-12-02



PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (CASUALTY)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

CASUALTY NO : 1

NAME : s.22

ADDRESS : 0 102 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

AGE : 213

GENDER : M

STATUS : CIVILIAN

DATE OF DEATH :

**Code Name : Code Description**

NATURE OF CASUALTY : 002 - LIGHT INJURY (HOSP. 1-2 DAYS AND/OR OFF WORK 1-15 DAYS)

CONDITION OF CASUALTY : 011 - ASLEEP AT TIME OF FIRE

ACTION OF CASUALTY : 021 - INJURED WHILE ATTEMPTING TO ESCAPE

IGNITION OF CLOTHING : 030 - NOT APPLICABLE

TYPE OF FABRIC IGNITED : 040 - NOT APPLICABLE

CAUSE OF FAILURE TO ESCAPE : 059 - UNCLASSIFIED OR NOT APPLICABLE

CAUSE OF INJURY/DEATH : 100 - SMOKE INHALATION

CASUALTY NO : 2

NAME : s.22

ADDRESS : 0 102 1400 WINDGROVE STREET  
NANAIMO BRITISH COLUMBIA

AGE : 213

GENDER : M

STATUS : CIVILIAN

DATE OF DEATH :

**Code Name : Code Description**

NATURE OF CASUALTY : 002 - LIGHT INJURY (HOSP. 1-2 DAYS AND/OR OFF WORK 1-15 DAYS)

CONDITION OF CASUALTY : 011 - ASLEEP AT TIME OF FIRE

ACTION OF CASUALTY : 023 - VOLUNTARILY ENTERED OR REMAINED FOR RESCUE PURPOSE

IGNITION OF CLOTHING : 030 - NOT APPLICABLE

TYPE OF FABRIC IGNITED : 040 - NOT APPLICABLE

CAUSE OF FAILURE TO ESCAPE : 059 - UNCLASSIFIED OR NOT APPLICABLE

CAUSE OF INJURY/DEATH : 100 - SMOKE INHALATION

Investigating Officer  
MOND, ENNIS

LAFC Badge #  
1030

Telephone  
250-753-7311

ReportDate  
2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (CASUALTY)

INCIDENT NUMBER: **CNA 2013 10 19 08 02**

CASUALTY NO : 3

NAME : **s.22**

ADDRESS : 0 101 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

AGE : 213

GENDER : M

STATUS : CIVILIAN

DATE OF DEATH :

**Code Name : Code Description**

NATURE OF CASUALTY : 002 - LIGHT INJURY (HOSP. 1-2 DAYS AND/OR OFF WORK 1-15 DAYS)

CONDITION OF CASUALTY : 011 - ASLEEP AT TIME OF FIRE

ACTION OF CASUALTY : 023 - VOLUNTARILY ENTERED OR REMAINED FOR RESCUE PURPOSE

IGNITION OF CLOTHING : 030 - NOT APPLICABLE

TYPE OF FABRIC IGNITED : 040 - NOT APPLICABLE

CAUSE OF FAILURE TO ESCAPE : 059 - UNCLASSIFIED OR NOT APPLICABLE

CAUSE OF INJURY/DEATH : 100 - SMOKE INHALATION

CASUALTY NO : 4

NAME : **s.22**

ADDRESS : 0 101 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

AGE : 213

GENDER : M

STATUS : CIVILIAN

DATE OF DEATH :

**Code Name : Code Description**

NATURE OF CASUALTY : 002 - LIGHT INJURY (HOSP. 1-2 DAYS AND/OR OFF WORK 1-15 DAYS)

CONDITION OF CASUALTY : 011 - ASLEEP AT TIME OF FIRE

ACTION OF CASUALTY : 023 - VOLUNTARILY ENTERED OR REMAINED FOR RESCUE PURPOSE

IGNITION OF CLOTHING : 030 - NOT APPLICABLE

TYPE OF FABRIC IGNITED : 040 - NOT APPLICABLE

CAUSE OF FAILURE TO ESCAPE : 059 - UNCLASSIFIED OR NOT APPLICABLE

CAUSE OF INJURY/DEATH : 100 - SMOKE INHALATION

Investigating Officer  
MOND, ENNIS

LAFC Badge #  
1030

Telephone  
250-753-7311

ReportDate  
2013-12-02

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (CASUALTY)

INCIDENT NUMBER: CNA 2013 10 19 08 02

CASUALTY NO : 5

NAME : s.22

ADDRESS : 0 103 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

AGE : 213

GENDER : M

STATUS : CIVILIAN

DATE OF DEATH :

**Code Name : Code Description**

NATURE OF CASUALTY : 002 - LIGHT INJURY (HOSP. 1-2 DAYS AND/OR OFF WORK 1-15 DAYS)

CONDITION OF CASUALTY : 011 - ASLEEP AT TIME OF FIRE

ACTION OF CASUALTY : 021 - INJURED WHILE ATTEMPTING TO ESCAPE

IGNITION OF CLOTHING : 030 - NOT APPLICABLE

TYPE OF FABRIC IGNITED : 040 - NOT APPLICABLE

CAUSE OF FAILURE TO ESCAPE : 059 - UNCLASSIFIED OR NOT APPLICABLE

CAUSE OF INJURY/DEATH : 100 - SMOKE INHALATION

CASUALTY NO : 6

NAME : s.22

ADDRESS : 0 103 1400 WINGROVE STREET  
NANAIMO BRITISH COLUMBIA

AGE : 213

GENDER : M

STATUS : CIVILIAN

DATE OF DEATH :

**Code Name : Code Description**

NATURE OF CASUALTY : 002 - LIGHT INJURY (HOSP. 1-2 DAYS AND/OR OFF WORK 1-15 DAYS)

CONDITION OF CASUALTY : 011 - ASLEEP AT TIME OF FIRE

ACTION OF CASUALTY : 021 - INJURED WHILE ATTEMPTING TO ESCAPE

IGNITION OF CLOTHING : 030 - NOT APPLICABLE

TYPE OF FABRIC IGNITED : 040 - NOT APPLICABLE

CAUSE OF FAILURE TO ESCAPE : 059 - UNCLASSIFIED OR NOT APPLICABLE

CAUSE OF INJURY/DEATH : 100 - SMOKE INHALATION

Investigating Officer  
MOND, ENNIS

LAFC Badge #  
1030

Telephone  
250-753-7311

ReportDate  
2013-12-02

