

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE

INCIDENT NUMBER: NVV 2014 09 13 04 01

Location of Incident: **3052 CAPOSTINSKY RD
VAVENBY BC V0E3A0**

of Occupants (At time of fire): **0** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **\$22**

Related to Wildland Interface Fire: **NO** Property Value: **\$0** Content Value: **\$0** Total Value at Risk: **\$0**

Code Name : **Code Description**

PROPERTY COMPLEX : 3400 RESIDENTIAL - SINGLE DETACHED
PROPERTY CLASSIFICATION : 3110 YEAR-ROUND USE DWELLING - 1-FAMILY
GENERAL CONSTRUCTION : 0009 GENERAL CONSTRUCTION - UNCLASSIFIED (DESCRIBE)
BUILDING HEIGHT : 0010 1 STORY ABOVE GRADE
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)
YEAR OF CONSTRUCTION : 0000 CANNOT BE DETERMINED
MANUAL FIRE PROTECTION : 4000 EXTINGUISHER ONLY
OUTSIDE FIRE PROTECTION : 7000 FIRE DEPARTMENT ONLY
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 0000 ALARM OPERATION CANNOT BE DETERMINED
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 2000 VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT ONLY
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4900 FIRE DEPARTMENT - WATER APPLICATION - UNCLASSIFIED (DESCRIBE)
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)
FIRE ORIGIN, AREA : 1400 LOUNGE, LIVING ROOM - INCLUDES MUSIC ROOM, COMMON ROOM, TV R
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN
EXTENT OF DAMAGE : 1000 CONFINED TO OBJECT OF ORIGIN
IGNITING OBJECT : 5110 PERMANENT ELECTRIC WIRING, CABLE (ALUMINUM)
FUEL OR ENERGY : 6000 ELECTRICITY
FORM OF HEAT : 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI
MATERIAL FIRST IGNITED : 0000 CANNOT BE DETERMINED
ACT OR OMISSION : 0000 CANNOT BE DETERMINED

Investigating Officer LAFC Badge #
MEYER, CST. JAY 57671

Telephone ReportDate
250-674-2237 2014-12-04

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)


INCIDENT NUMBER: **NVV 2014 09 13 04 01**

Remarks:

ADVISED OF RESIDENTIAL FIRE BY A CANFOR EMPLOYEE, CONFIRMED NO ONE IN RESIDENCE. NEIGHBOURS ADVISED THAT OWNER/SON AWAY CAMPING FOR THE WEEKEND. VAVENBY FIRE DEPT, AMBULANCE, BC HYDRO, POLICE ON SCENE. POLICE SPOKE WITH FIRE CHIEF THOUGHT MAY HAVE BEEN AN ELECTIRCAL FIRE THAT STARTED IN THE LIVING ROOM. INSURANCE FIRE INVESTIGATOR ATTENDED. FIRE DID NOT SPREAD TO OUTBUILDINGS. OLD HOME WITH SAWDUST INSULATION IN WALLS.

Investigating Officer
MEYER, CST. JAY

LAFC Badge #
57671

Telephone
250-674-2237 

ReportDate
2014-12-04

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **NVV 2014 09 13 04 01**

Name no. : 1
Name : **s.22**
Address : 3052 CAPOSTINSKY RD
VAVENBY BRITISH COLUMBIA

Name Status : OWNER
Phone : **s.22**

Claims Adjuster Name : 1. ANDERSON , FRASER A.
Claims Adjuster Firm : 1. HUSTON GRANT
Claim Number :
Insurance Company : 1. HUSTON GRANT ADJUSTERS
Policy Number :

LOSS ESTIMATES:

Property Loss : \$**s.22**

Content Loss : \$**s.22**

Total Loss : \$**s.22**

REMARKS:

Investigating Officer
MEYER, CST. JAY

LAFC Badge #
57671

Telephone
250-674-2237 

ReportDate
2014-12-04

