

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

## FIRE REPORT - STRUCTURE

INCIDENT NUMBER: CNW 2014 12 02 02 03

Location of Incident: **728 PRINCESS ST  
NEW WESTMINSTER BC**

# of Occupants (At time of fire): **140** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **s.22**

Related to Wildland Interface Fire: **NO** Property Value: **s.22** Content Value: **\$0** Total Value at Risk: **s.22**

**Code Name : Code Description**

PROPERTY COMPLEX : 3200 RESIDENTIAL - APARTMENT  
PROPERTY CLASSIFICATION : 3250 APARTMENT, TOWNHOUSE - OVER 20 UNITS WITH OR W/O BUSINESS  
GENERAL CONSTRUCTION : 5000 PROTECTED NON-COMBUSTIBLE CONSTRUCTION - PROTECTED STEEL OR  
BUILDING HEIGHT : 0150 15 STORIES ABOVE GRADE  
GROUND FLOOR AREA : 3000 501 TO 1000M2 (5383 - 10764FT2)  
YEAR OF CONSTRUCTION : 2000 2000  
MANUAL FIRE PROTECTION : 6000 STANDPIPE SYSTEM ONLY  
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT  
SPRINKLER PROTECTION : 1000 COMPLETE SPRINKLER PROTECTION - SUPERVISED (ON-SITE OR OFF-S  
AUTOMATIC FIRE ALARM SYSTE : 3000 FIRE ALARM SYSTEM - OFF-SITE MONITORING AGENCY  
SMOKE ALARM OPERATION : 0000 ALARM OPERATION CANNOT BE DETERMINED  
INITIAL DETECTION : 2000 SMOKE DETECTOR DEVICE  
TRANSMISSION OF ALARM : 1000 911  
FIRE SERVICE : 1000 CAREER FIRE DEPARTMENT ONLY  
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED  
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT  
METHOD OF FIRE CONTROL : 6100 WET PIPE SYSTEM - INCLUDES CENTRAL STATION SUPERVISED OR WAT  
FIRE ORIGIN, LEVEL : 6000 4TH TO 12TH STOREY (INCLUSIVE) OR OVER 9M TO 36M (30FT TO 12  
FIRE ORIGIN, AREA : 5900 SERVICE FACILITIES - UNCLASSIFIED (DESCRIBE)  
EXTENT OF FIRE : 2000 CONFINED TO PART OF ROOM/AREA OF ORIGIN  
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN  
IGNITING OBJECT : 5900 ELECTRICAL DISTRIBUTION EQUIPMENT - UNCLASSIFIED (DESCRIBE)  
FUEL OR ENERGY : 6000 ELECTRICITY  
FORM OF HEAT : 2000 SPARK, ELECTRICAL - INCLUDES ARC, DISCHARGE. (EXCLUDES STATI  
MATERIAL FIRST IGNITED : 9500 INSULATION, ELECTRIC - CONFINED TO ELECTRICAL EQUIPMENT - IN  
ACT OR OMISSION : 4400 ELECTRICAL SHORT CIRCUIT

Investigating Officer LAFC Badge #  
WILSON, DAN 2652

Telephone ReportDate  
604-519-1000 2015-04-28

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **CNW 2014 12 02 02 03**


---

**Remarks:**

---

Investigating Officer  
WILSON, DAN

L AFC Badge #  
2652

Telephone  
604-519-1000 

ReportDate  
2015-04-28

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CNW 2014 12 02 02 03**

Name no. : 1  
Name : **s.22**  
Address :

Name Status : BUSINESS OWNER  
Phone : **s.22**

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:  
Property Loss : **s.21**

Content Loss : \$0

Total Loss : **s.21**

REMARKS:

Name no. : 2  
Name : UNKNOWN, UNKNOWN  
Address : 0

Name Status : OCCUPANT  
Phone :

Claims Adjuster Name :  
Claims Adjuster Firm :  
Claim Number :  
Insurance Company :  
Policy Number :

LOSS ESTIMATES:  
Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

Investigating Officer : LAFB Badge #  
WILSON, DAN : 2652

Telephone : ReportDate  
604-519-1000  2015-04-28

PROVINCE OF BRITISH COLUMBIA  
Ministry of Justice  
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (CASUALTY)

INCIDENT NUMBER: **CNW 2014 12 02 02 03**

CASUALTY NO : 1  
NAME : UNKNOWN, UNKNOWN  
ADDRESS : 0


AGE : 215  
GENDER : F  
STATUS : CIVILIAN  
DATE OF DEATH :

**Code Name : Code Description**

NATURE OF CASUALTY : 003 - MINOR INJURY (LESS THAN ONE DAY HOSPITAL OR OFF WORK)  
CONDITION OF CASUALTY : 010 - CONDITION OF CASUALTY UNKNOWN  
ACTION OF CASUALTY : 021 - INJURED WHILE ATTEMPTING TO ESCAPE  
IGNITION OF CLOTHING : 030 - NOT APPLICABLE  
TYPE OF FABRIC IGNITED : 040 - NOT APPLICABLE  
CAUSE OF FAILURE TO ESCAPE : 050 - UNKNOWN  
CAUSE OF INJURY/DEATH : 108 - UNKNOWN

Investigating Officer  
WILSON, DAN

LAFC Badge #  
2652

Telephone  
604-519-1000 

ReportDate  
2015-04-28

