

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE

INCIDENT NUMBER: CSY 2015 08 27 16 08

Location of Incident: **9055 147 ST
SURREY BC**

of Occupants (At time of fire): **4** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **\$ 22**

Related to Wildland Interface Fire: **NO** Property Value: **\$22** Content Value: **\$22** Total Value at Risk: **\$22**

Code Name : Code Description

PROPERTY COMPLEX : 3400 RESIDENTIAL - SINGLE DETACHED
PROPERTY CLASSIFICATION : 3110 YEAR-ROUND USE DWELLING - 1-FAMILY
GENERAL CONSTRUCTION : 1000 COMBUSTIBLE CONSTRUCTION - OPEN WOOD JOIST
BUILDING HEIGHT : 0020 2 STORIES ABOVE GRADE
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)
YEAR OF CONSTRUCTION : 2001 2001
MANUAL FIRE PROTECTION : 7000 NO MANUAL FIRE PROTECTION
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTE : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 1000 ALARM ACTIVATED - ASSISTED OCCUPANT(S) IN EVACUATING
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 3000 COMPOSITE - CAREER & VOLUNTEER/PAID-ON-CALL FIRE DEPARTMENT
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4300 38MM/42MM (1 1/2"/1 3/4") HOSE - 2 OR MORE HAND LINES
FIRE ORIGIN, LEVEL : 8000 ROOF LEVEL - INCLUDES CONCEALED ROOF SPACE, ATTIC
FIRE ORIGIN, AREA : 7400 CEILING & ROOF/CEILING SPACE (ATTIC)
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN
EXTENT OF DAMAGE : 5000 CONFINED TO BUILDING OF ORIGIN
IGNITING OBJECT : 7700 TORCH - OTHER THAN CUTTING, WELDING - INCLUDES PLUMBER'S FUR
FUEL OR ENERGY : 4200 FUEL GAS - PROPANE
FORM OF HEAT : 4000 DIRECT FLAME
MATERIAL FIRST IGNITED : 2000 ROOF COVERING - OTHER THAN WOOD
ACT OR OMISSION : 7700 IGNORANCE OF HAZARD (NOTE: IF ILLEGAL OPERATIONS, CLASSIFY A

Investigating Officer	L AFC Badge #	Telephone	ReportDate
SHEEL, DANIEL	1810	604-543-6700	2015-08-31

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **CSY 2015 08 27 16 08**

Remarks:

FIRE STARTED ON THE ROOF. SUSPECT ROOF STARTED FIRE WITH TORCH. INFORMATION FROM OWNER, AND FIRE CREW.

Investigating Officer	L AFC Badge #	Telephone	ReportDate
SHEEL, DANIEL	1810	604-543-6700	2015-08-31

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)INCIDENT NUMBER: **CSY 2015 08 27 16 08**

Name no. : 1
Name : s.22
Address : 0

Name Status : OWNER
Phone :

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : s.22

Content Loss s.22

Total Loss : s.22

REMARKS:

Investigating Officer : LAFC Badge #
SHEEL, DANIEL : 1810

Telephone : ReportDate
604-543-6700 : 2015-08-31

