

(CVIS complaint #1406):

1406	South Coast	01-Dec-14	BRITANNIA BEACH	s.22	<p>Details: Advised that during a PH alarm yesterday (possibly caused by power outage or spike) monitoring indicated that for a 2 hour duration PH levels exceeded allowable levels. Permitted PH is 9.5 and during the incident, the levels were as high as 9.61. The receiving environment was the marine.</p> <p>Response: Staff investigating the incident.</p>	EPCOR	Municipal Sewage Management	Effluent
------	-------------	-----------	-----------------	------	---	-------	-----------------------------	----------