



Event History Report

Selection Summary

Selection Date
Compare Due With Date
Date From
Date To
Time From
Time To
Time Range

Started
29/03/2017
25/05/2017
00:00
23:59

Include

Event Summary
Instruction Details
Remarks
Notes

✓
✓
✓
✓

Additional Visits
Costs
Subsidiary Assets
Elapsed Time

Group By

Page On

Value From

Value To



Event History Report

Date From 29/03/2017 Date To 25/05/2017

| Service Event | | 5514 | | | Status : Completed |
|---------------|-------------------|-----------------|----------------------|--------------|--------------------|
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | b | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |

Division UserID Josee Porterfield

Geography OCC/Pod C/Level 1/CW119 Food Cart Storage

Works Order Number Project Number Overdue :No

Maintenance to circuit breakers Estimated Cost \$0.00

Reported 29/Mar/2017 08:40 Notified 29/Mar/2017 08:40 Due 01/Apr/2017 20:40 Started 29/Mar/2017 08:41 Completed 29/Mar/2017 11:46 RTS

Instructions Breaker blown in CW food service area.

Event Remarks 29/03/2017 Don Kachel: investigating
29/03/2017 Don Kachel: Two microwaves plugged into same circuit. Moved the microwave to other location where it is suppose to be . reset the breaker .

Service Event 5561 Status : Completed

Requested By Normand Martin Contractor Honeywell Team Assigned To
Reference Contractor Type Link
On Behalf Of Normand Martin Work Type Availability Routine Allocation
Service Group Electrical Int Priority b Cost Code
Service Circuit Breaker Department Satisfaction
Division UserID Normand Martin
Geography OCC/Pod A/Level 2/AE210 Cell

Works Order Number Project Number Overdue :No

Maintenance to circuit breakers Estimated Cost \$0.00

Reported 31/Mar/2017 15:51 Notified 31/Mar/2017 15:51 Due 04/Apr/2017 03:51 Started 31/Mar/2017 15:52 Completed 31/Mar/2017 16:27 RTS

Instructions Breaker is tripped and needs to be reset.

Event Remarks 31/03/2017 Peter Eyzenga: Went to investigate & found s.15 removed s.15 and reset breaker. (0.5 HR) Complete.

Service Event 5697 Status : Completed

Requested By Normand Martin Contractor Honeywell Team Assigned To

| | | | | | |
|---------------------------|---|------------------------|------------------------------|---------------------|----------------|
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Normand Martin | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | 8 | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Normand Martin |
| | | Geography | OCC/Pod C/Level 1/CE104 Cell | | |
| Works Order Number | | Project Number | | Overdue | :No |
| | Maintenance to circuit breakers | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS |
| 07/Apr/2017 07:18 | 07/Apr/2017 07:18 | 09/Apr/2017 07:18 | 07/Apr/2017 07:19 | 07/Apr/2017 08:17 | |
| Instructions | Breaker requires reset, no power to the cell. | | | | |
| Event Remarks | 07/04/2017 Peter Eyzenga investigating. found s.15 , removed it and reset breaker. 0.5 HR Complete. | | | | |

| | | | | | |
|---------------------------|---------------------------------|---------------------------|------------------------------|---------------------|-------------------|
| Service Event | 5796 | Status : Completed | | | |
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | 8 | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Josee Porterfield |
| | | Geography | OCC/Pod C/Level 2/CE204 Cell | | |
| Works Order Number | | Project Number | | Overdue | :No |
| | Maintenance to circuit breakers | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS |
| 11/Apr/2017 10:10 | 11/Apr/2017 10:10 | 13/Apr/2017 10:10 | 11/Apr/2017 10:11 | 11/Apr/2017 13:26 | |

Instructions CE cell204 possible blown breaker.

Event Remarks 11/04/2017 John Benson: is investigating Checked receptacle I for s.15 and found nothing. reset breaker. Complete.

Service Event 5839 **Status : Completed**

| | | | | | |
|----------------------|-------------------|------------------------|------------------------------|---------------------|-------------------|
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | b | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Josee Porterfield |
| | | Geography | OCC/Pod C/Level 1/CW105 Cell | | |

| | | | | | |
|---------------------------|---------------------------------|-----------------------|--------|----------------|----|
| Works Order Number | | Project Number | | Overdue | No |
| | Maintenance to circuit breakers | Estimated Cost | \$0.00 | | |

| | | | | | |
|-------------------|-------------------|-------------------|-------------------|-------------------|------------|
| Reported | Notified | Due | Started | Completed | RTS |
| 13/Apr/2017 15:40 | 13/Apr/2017 15:40 | 17/Apr/2017 03:40 | 13/Apr/2017 15:41 | 13/Apr/2017 16:47 | |

Instructions CW cell 105 Possible breaker blown.

Event Remarks 13/04/2017 Brian Anderson: GFCI in cell chase was tripped due to s.15 being jammed in the receptacle in the cell.Dug s.15 out of receptacle in cell and reset GFCI in cell chase.Did the same procedure for cell CW112 while I was on the unit because an inmate complained he was getting shocked from it while he was sleeping at night.(Malicious Damage. 1HOUR) s.15 Complete. (1)

Service Event 5991 **Status : Completed**

| | | | | | |
|----------------------|-------------------|------------------------|------------------------------|---------------------|-------------------|
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | 8 | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Josee Porterfield |
| | | Geography | OCC/Pod C/Level 2/CE212 Cell | | |

| | | | | | |
|---------------------------------|--|-------------------|-------------------|-------------------|-----|
| Works Order Number | | Project Number | | Overdue :No | |
| Maintenance to circuit breakers | | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS |
| 22/Apr/2017 07:05 | 22/Apr/2017 07:05 | 24/Apr/2017 07:05 | 22/Apr/2017 07:06 | 22/Apr/2017 14:42 | |
| Instructions | CE Cell 212 the breaker may be off. | | | | |
| Event Remarks | 22/04/2017 Brian Anderson: Investigating 22/04/2017 Brian Anderson: Receptacle in cell212 has been compromised by s.15 Unsafe to re energize at this time.Receptacle is damaged and should be replaced. 22/04/2017 14:40 (UTC -7) Tim Birmingham: Removed any existing s.15 and reset G.F.I. Malicious damage 0.5 hrs. | | | | |

| | | | | | |
|----------------------|-------------|---------------------------|--|--|--|
| Service Event | 5994 | Status : Completed | | | |
|----------------------|-------------|---------------------------|--|--|--|

| | | | | | |
|----------------------|-------------------|------------------------|------------------------------|---------------------|-------------------|
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | 8 | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Josee Porterfield |
| | | Geography | OCC/Pod C/Level 2/CE212 Cell | | |

| | | | | | |
|---------------------------------|--|-------------------|-------------------|-------------------|-----|
| Works Order Number | | Project Number | | Overdue :No | |
| Maintenance to circuit breakers | | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS |
| 22/Apr/2017 12:04 | 22/Apr/2017 12:04 | 24/Apr/2017 12:04 | 22/Apr/2017 12:05 | 22/Apr/2017 12:34 | |
| Instructions | The breaker has blown in CE 212 .l | | | | |
| Event Remarks | 22/04/2017 Brian Anderson:This is a duplicated event(see 5991).Complete. | | | | |

| | | | | | |
|----------------------|-------------|---------------------------|--|--|--|
| Service Event | 6268 | Status : Completed | | | |
|----------------------|-------------|---------------------------|--|--|--|

| | | | | | |
|---------------------|---------------|------------------------|----------------|--------------------|--|
| Requested By | Barry Wilkins | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |

| | | | | | |
|---------------------------|---|-----------------------|------------------------------|---------------------|-----------------|
| On Behalf Of | Barry Wilkins | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | b | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | samander mirzad |
| | | Geography | OCC/Pod A/Level 3/AW310 Cell | | |
| Works Order Number | | Project Number | | Overdue | :No |
| | Maintenance to circuit breakers | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS |
| 29/Apr/2017 17:05 | 29/Apr/2017 17:05 | 03/May/2017 05:05 | 29/Apr/2017 17:06 | 29/Apr/2017 18:16 | |
| Instructions | ext: 2000 ~ no electricity in the room. | | | | |
| Event Remarks | 29/04/2017 Peter Eyzenga; is investigating, Receptacle has bad burn marks but there was no sign of ^{s.15} . Reset and is working at this time. .5 Complete | | | | |

| | | |
|----------------------|-------------|---------------------------|
| Service Event | 6364 | Status : Completed |
|----------------------|-------------|---------------------------|

| | | | | | |
|---------------------------|--|------------------------|---------------------------------|---------------------|-------------------|
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | b | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Josee Porterfield |
| | | Geography | OCC/Pod A/Level 1/SM100 Dayroom | | |
| Works Order Number | | Project Number | | Overdue | :No |
| | Maintenance to circuit breakers | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS |
| 05/May/2017 13:11 | 05/May/2017 13:38 | 09/May/2017 01:11 | 05/May/2017 13:38 | 05/May/2017 14:42 | |
| Instructions | Possible breaker blown where the coffee pot is plugged in Smu Common Area kitchen. | | | | |
| Event Remarks | 05/05/2017 Don Kachel: Went to coffee area and found kettle plugged into coffee pot circuit. Breaker overloaded. moved kettle to other receptacle . 1/2 hour | | | | |

| Service Event | | 6568 | | | | Status : Completed | |
|--------------------|---|-------------------|-------------------|------------------------------|-------------|--------------------|-------------------|
| Requested By | Josee Porterfield | | Contractor | Honeywell Team | | Assigned To | |
| Reference | | | Contractor Type | | | Link | |
| On Behalf Of | Josee Porterfield | | Work Type | Availability Routine | | Allocation | |
| Service Group | Electrical Int | | Priority | b | | Cost Code | |
| Service | Circuit Breaker | | Department | | | Satisfaction | |
| | | | Division | | | UserID | Josee Porterfield |
| | | | Geography | OCC/Pod A/Level 3/AW311 Cell | | | |
| Works Order Number | | | Project Number | | Overdue :No | | |
| | Maintenance to circuit breakers | | Estimated Cost | \$0.00 | | | |
| Reported | Notified | Due | Started | Completed | RTS | | |
| 13/May/2017 13:28 | 13/May/2017 13:28 | 17/May/2017 01:28 | 13/May/2017 13:29 | 16/May/2017 10:12 | | | |
| Instructions | TV is not working, breaker needs to be fixed. (HK) | | | | | | |
| Event Remarks | 13/05/2017 15:23 (UTC -7) Brian Anderson: Went toAW311to find cell power tripped.Upon inspection I found a scorched receptacle with ^{s.15} protruding from it.I deemed it to be unsafe in accordance with rule 2-300(1) and 2-300(4) of the Canadian Electrical Code.This event will need to be addressed by an electrical contractor. 16/05/2017 John Benson: we will not be able to reset the breaker as per rule above and changing a damaged recepticle requires a ticketed trades person. This is malicious damage. 16/05/2017 Steve Schindel: Plug has been replaced due to malicious damage. Plug plate has been re-caulked(security caulk). Plug has been tested. Completed (1Hr). | | | | | | |

| Service Event | | 6612 | | | Status : Completed | |
|---------------|-------------------|-----------------|---|--------------------------|--------------------|--|
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | | |
| Reference | | Contractor Type | | Link | | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | | |
| Service Group | Electrical Int | Priority | b | Cost Code | | |
| Service | Circuit Breaker | Department | | Satisfaction | | |
| | | Division | | UserID Josee Porterfield | | |
| | | Geography | OCC/Pod A/Level 1/AW119 Food Cart Storage | | | |

| | | | | | | |
|---------------------------|---|-------------------|-----------------------|-------------------|------------|-------------|
| Works Order Number | | | Project Number | | | Overdue :No |
| | Maintenance to circuit breakers | | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS | |
| 14/May/2017 13:50 | 14/May/2017 13:50 | 18/May/2017 01:50 | 14/May/2017 13:51 | 14/May/2017 15:59 | | |
| Instructions | Middle plug in the common area kitchen AW breaker blown. (HK) | | | | | |
| Event Remarks | 14/05/2017 Brian Anderson: Reset tripped breaker.Checked receptacle.Complete.(.5) | | | | | |

| | | | | | |
|----------------------|-----------------|---------------------------|------------------------------|---------------------|----------------|
| Service Event | 6689 | Status : Completed | | | |
| Requested By | Normand Martin | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Normand Martin | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | b | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Normand Martin |
| | | Geography | OCC/Pod A/Level 1/AW106 Cell | | |

| | | | | | | |
|---------------------------|---|-------------------|-----------------------|-------------------|------------|-------------|
| Works Order Number | | | Project Number | | | Overdue :No |
| | Maintenance to circuit breakers | | Estimated Cost | \$0.00 | | |
| Reported | Notified | Due | Started | Completed | RTS | |
| 18/May/2017 07:47 | 18/May/2017 07:47 | 21/May/2017 19:47 | 18/May/2017 07:48 | 18/May/2017 15:07 | | |
| Instructions | Breaker requires resetting. | | | | | |
| Event Remarks | 18/05/2017) John Benson: is investigating and found the receptical was black . The inmate in the room said he just moved in but the receptical will need to be replaced by an electrician. I did not reset the breaker. pic attatached | | | | | |
| | 18/05/2017 Steve S: Investigated by Fm found s.15 stuck in receptacle. Turned power off to plug and replaced with new receptacle and applied security caulking, verified power is working. (1 hour) | | | | | |

| | | | | | |
|----------------------|-------------------|---------------------------|----------------|--------------------|--|
| Service Event | 6766 | Status : Completed | | | |
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |

| | | | | | |
|----------------------|-------------------|------------------------|------------------------------|---------------------|-------------------|
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | 8 | Cost Code | |
| Service | Circuit Breaker | Department | | Satisfaction | |
| | | Division | | UserID | Josee Porterfield |
| | | Geography | OCC/Pod A/Level 2/SM209 Cell | | |

| | | | | |
|---------------------------|---------------------------------|-----------------------|--------|-------------|
| Works Order Number | | Project Number | | Overdue :No |
| | Maintenance to circuit breakers | Estimated Cost | \$0.00 | |

| | | | | | |
|-------------------|-------------------|-------------------|-------------------|-------------------|------------|
| Reported | Notified | Due | Started | Completed | RTS |
| 20/May/2017 14:09 | 20/May/2017 14:09 | 22/May/2017 14:09 | 20/May/2017 14:10 | 20/May/2017 14:52 | |

Instructions SMU Cell 209 possible breaker blown.

Event Remarks 20/05/2017 Craig Heppner: Investigating :breaker was okay;(5)

Service Event **6810** **Status : Completed**

| | | | | | |
|----------------------|-------------------|------------------------|------------------------------|---------------------|-------------------|
| Requested By | Josee Porterfield | Contractor | Honeywell Team | Assigned To | |
| Reference | | Contractor Type | | Link | |
| On Behalf Of | Josee Porterfield | Work Type | Availability Routine | Allocation | |
| Service Group | Electrical Int | Priority | b | Cost Code | |
| Service | Systems Other | Department | | Satisfaction | |
| | | Division | | UserID | Josee Porterfield |
| | | Geography | OCC/Pod A/Level 1/AE108 Cell | | |

| | | | | |
|---------------------------|---------------|-----------------------|--------|-------------|
| Works Order Number | | Project Number | | Overdue :No |
| | Systems Other | Estimated Cost | \$0.00 | |

| | | | | | |
|-------------------|-------------------|-------------------|-------------------|-------------------|------------|
| Reported | Notified | Due | Started | Completed | RTS |
| 23/May/2017 10:14 | 23/May/2017 10:23 | 26/May/2017 22:14 | 23/May/2017 10:23 | 25/May/2017 14:05 | |

Instructions The lower socket/outlet in cell 108 on the bottom bunk shocks the I/M that resides in that cell if he accidentally leans back on his pillow and his head touches the outlet.

Please let Honeywell know to come and investigate or if it is possible to cut the power to the socket so it stops zapping him?

Event Remarks

24/05/2017 John Benson: I spoke to Miss Porterfield yesterday and asked her if there is anything that can be done about this continuing problem, she was going to check and get back to me.

24/05/2017 Craig Heppner: Investigating Found s.15 sticking out of receptacle, removed lead so he would not get another shock ! Complete (.5)

25/05/2017 Steve Schindel: Checked and confirmed 120Vac. Turned off breaker. Verified power had been turned off at receptacle. Replaced receptacle. Turned breaker back on. Verified 120Vac at plug. Event closed (1Hr).