

Location of Incident: **3526 SMITH  
BURNABY BC**

# of Occupants (At time of fire): **75** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimate: **\$2,100,000**

Related to Wildland Interface Fire: **NO** Property Value: **\$2,000,000** Content Value: **\$250,000** Total Value at Risk: **\$2,250,000**

**Code Name : Code Description**

PROPERTY COMPLEX : 3200 RESIDENTIAL - APARTMENT  
PROPERTY CLASSIFICATION : 3250 APARTMENT, TOWNHOUSE - OVER 20 UNITS WITH OR W/O BUSINESS  
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST  
BUILDING HEIGHT : 0030 3 STORIES ABOVE GRADE  
GROUND FLOOR AREA : 3000 501 TO 1000M2 (5383 - 10764FT2)  
YEAR OF CONSTRUCTION : 0051 1951 TO 1960  
MANUAL FIRE PROTECTION : 4000 EXTINGUISHER ONLY  
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT  
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION  
AUTOMATIC FIRE ALARM SYSTE : 2000 FIRE ALARM SYSTEM - LOCAL (BUILDING ONLY)  
SMOKE ALARM OPERATION : 1000 ALARM ACTIVATED - ASSISTED OCCUPANT(S) IN EVACUATING  
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S  
TRANSMISSION OF ALARM : 1000 911  
FIRE SERVICE : 1000 CAREER FIRE DEPARTMENT ONLY  
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED  
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT  
METHOD OF FIRE CONTROL : 4700 COMBINATIONS OF 38/42MM (1 1/2"/1 3/4"), 65MM (2 1/2"), 7  
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)  
FIRE ORIGIN, AREA : 0000 CANNOT BE DETERMINED  
EXTENT OF FIRE : 5000 CONFINED TO BUILDING OF ORIGIN  
EXTENT OF DAMAGE : 6000 EXTENDED BEYOND BUILDING OF ORIGIN  
IGNITING OBJECT : 0000 CANNOT BE DETERMINED  
FUEL OR ENERGY : 0000 CANNOT BE DETERMINED  
FORM OF HEAT : 0000 CANNOT BE DETERMINED  
MATERIAL FIRST IGNITED : 0000 CANNOT BE DETERMINED  
ACT OR OMISSION : 0000 CANNOT BE DETERMINED

Investigating Officer LAFC Badge #  
FOSTER, R 1941

Telephone ReportDate  
604-294-7195 2013-02-21

