

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - STRUCTURE

INCIDENT NUMBER: CPC 2015 07 30 06 01

Location of Incident:

**2630 SHAUGHNESSY STREET
PORT COQUITLAM BC V3C3G6**

of Occupants (At time of fire): **1** # of Injured: **0** # of Deaths: **0** Total Dollar Loss Estimated: **\$22**

Related to Wildland Interface Fire: **NO** Property Value: **\$22** Content Value: **\$0** Total Value at Risk: **\$22**

Code Name : Code Description

PROPERTY COMPLEX : 5700 COMMERCIAL CENTRE, SHOPPING CENTRE, STRIP MALL
PROPERTY CLASSIFICATION : 4210 BARBER OR HAIRDRESSING ESTABLISHMENT ONLY
GENERAL CONSTRUCTION : 2000 PROTECTED COMBUSTIBLE CONSTRUCTION - WOOD PROTECTED BY PLAST
BUILDING HEIGHT : 0020 2 STORIES ABOVE GRADE
GROUND FLOOR AREA : 2000 101 TO 500M2 (1077 - 5382FT2)
YEAR OF CONSTRUCTION : 0046 1946 TO 1950
MANUAL FIRE PROTECTION : 4000 EXTINGUISHER ONLY
OUTSIDE FIRE PROTECTION : 1000 PUBLIC HYDRANT PROTECTION & FIRE DEPARTMENT
SPRINKLER PROTECTION : 7000 NO SPRINKLER PROTECTION
AUTOMATIC FIRE ALARM SYSTEM : 1000 NO FIRE ALARM SYSTEM
SMOKE ALARM OPERATION : 9500 ALARM NOT ACTIVATED - UNKNOWN
INITIAL DETECTION : 7000 VISUAL SIGHTING OR OTHER MEANS OF PERSONAL DETECTION (E.G. S
TRANSMISSION OF ALARM : 1000 911
FIRE SERVICE : 1000 CAREER FIRE DEPARTMENT ONLY
INCIDENT : 1000 FIRE - FIRE DEPARTMENT ATTENDED
ACTION TAKEN : 3000 EXTINGUISHED BY FIRE DEPARTMENT
METHOD OF FIRE CONTROL : 4700 COMBINATIONS OF 38/42MM (1 1/2"/1 3/4"), 65MM (2 1/2"), 7
FIRE ORIGIN, LEVEL : 3000 GROUND FLOOR, GRADE LEVEL OR GRADE TO 3M (10FT)
FIRE ORIGIN, AREA : 3900 FUNCTION AREA - UNCLASSIFIED (DESCRIBE)
EXTENT OF FIRE : 6000 EXTENDED BEYOND PROPERTY OF ORIGIN
EXTENT OF DAMAGE : 6000 EXTENDED BEYOND BUILDING OF ORIGIN
IGNITING OBJECT : 4990 APPLIANCES & EQUIPMENT - UNCLASSIFIED (DESCRIBE)
FUEL OR ENERGY : 6000 ELECTRICITY
FORM OF HEAT : 6000 HOT OBJECT - DIRECT HEAT BY CONDUCTION OR RADIATION, NO DIRE
MATERIAL FIRST IGNITED : 0000 CANNOT BE DETERMINED
ACT OR OMISSION : 3700 COMBUSTIBLE PLACED TOO CLOSE TO HEAT

Investigating Officer
NEIGHBOUR, SHAUN

LAFC Badge #
2137

Telephone
604-927-5466

ReportDate
2015-08-06

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NARRATIVE)

INCIDENT NUMBER: **CPC 2015 07 30 06 01**

Remarks:

ELECTRIC TOWEL WARMER LEFT ENERGIZED. LIT FACE TOWELS ON FIRE. FIRE SPREAD TO ADJACENT UNITS. SIX UNITS INVOLVED.

Investigating Officer	L AFC Badge #	Telephone	ReportDate
NEIGHBOUR, SHAUN	2137	604-927-5466	2015-08-06

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **CPC 2015 07 30 06 01**

Name no. : 1
Name : s.22
Address :

Name Status : OWNER
Phone : s.22

Claims Adjuster Name : 1. SAWADA , GARY
Claims Adjuster Firm : 1. AVIVA
Claim Number :
Insurance Company : 1. AVIVA CANADA INC.
Policy Number :

LOSS ESTIMATES:

Property Loss : s.22

Content Loss : \$0

Total Loss : s.22

REMARKS:

BASE BUILDING ESTIMATE ONLY.

Name no. : 2
Name : s.22
Address :

Name Status : WITNESS
Phone : s.22

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

INCIDENT COMMANDER.

Investigating Officer : LAFC Badge #
NEIGHBOUR, SHAUN : 2137

Telephone :
604-927-5466
ReportDate :
2015-08-06

PROVINCE OF BRITISH COLUMBIA
Ministry of Justice
Emergency Management BC / Office of the Fire Commissioner

FIRE REPORT - **STRUCTURE** (NAMES)

INCIDENT NUMBER: **CPC 2015 07 30 06 01**

Name no. : 3
Name : s.22
Address :

Name Status : WITNESS
Phone : s.22

Claims Adjuster Name :
Claims Adjuster Firm :
Claim Number :
Insurance Company :
Policy Number :

LOSS ESTIMATES:

Property Loss : \$0

Content Loss : \$0

Total Loss : \$0

REMARKS:

INSURANCE ADJUSTER FOR BASE BUILDING

Investigating Officer : LAFC Badge #
NEIGHBOUR, SHAUN : 2137

Telephone :
604-927-5466
ReportDate :
2015-08-06

