


Highways Electrical Work Order

Label	H20001 - 1728 Ryan Rd @ Back Rd MVI Callout
	D20006 - Ryan and Back MVA
	Wednesday, November 4th 2020, 8:39 AM (PST -08:00)

Progress Report

☒ In Progress

If so what needs to be completed? When will it be done?

Project will need to be created to replace damaged equipment

☒ Completed Ready for Billing

Location Information

Equipment ID

➤ Service Area 3 ➤ 1728 - RYAN - Back Rd @ Ryan Rd

Task ID

➤ Call Out


Cause

➤ Accident

Description of work

Description of Work

Respond to call out and turn off street light circuit. Remove damaged conductor re-splice streetlight conductors. Tape off damaged preemption. Both JB lids and top section are damaged. The spare JB which is empty has been temporarily was screwed so the lady is not a tripping hazard and JB with conductors in it is re-bolted however it Will require replacement. Collect and remove debris and reinstate street lighting





Damaged preemption



Remove broken street light feed conductors and resplice street lights



Reinstate Street light feed



Comments of any outstanding issues on site. Generate Flag and Follow up work order for any issues that need to be addressed using the correct form.

The pole and street light plus conductor will need to be replaced. Both JB lids and most likely both top sections. Preemption plus wiring. This was just a Plemon airy look further investigation during daylight required

Time Spent (total of everybody)

2

Date Completed

November 2, 2020

Time Completed

7:00 AM

Part Information For Items Used Such As UPS, Conflict Monitor, Controller, Etc.



Investigate clearances at adjacent pole due to removal of 8 m pole with updated 8.5 m pole replacement



Install new nuts & washers



Fuse holder & boot



Pole bond



New nut covers



Verify function



Add Bond for metal lid replacement

Part Information For Items Used Such As UPS, Conflict Monitor, Controller, Etc.

Worker / Vehicle Time

Repeat for each Worker

Worker

s.22

Date

November 4, 2020

Start Time

11:30 AM

Finish Time

3:30 PM

Total Regular Hours

4

Total Overtime Hours

No comments

Total Doubletime Hours

No comments

Vehicle

➤ Bucket Trucks ➤ S0439 - 2018 Ford F550 - Nanaimo

Vehicle Hours

4

Trailer

No comments

Trailer Hours

No comments

Worker / Vehicle Time

Repeat for each Worker

Worker

s.22

Date

November 4, 2020

Start Time

No comments

Job Comments

Subcontractors

s.22

Any information applicable with Subcontractors

Land closure Traffic control provided by Domcore

s.22



s.22

Journeyman Electrician

November 5th 2020, 10:27 AM (PST -08:00)



49.9745625, -125.2363657